

防爆形ベンチレーター 必要台数概算早見表

※仮に換気回数を15回／時、60Hz地区とした場合

容積 (m ³)			20	25	40	55	65	80	160	190	200	240	390	440	500	590	800
必要換気量 (m ³ /h)			300	375	600	825	975	1200	2400	2850	3000	3600	5850	6600	7500	8850	12000
型 式	ダクト径 (mm)	ダクト (m)															
S-200SP	200	3	1	2	2	3	3	4									
S-250SPW	200	3		1	2	2	3	3	6								
S-250SW	300	3			1	2	2	2	4	4							
S-300S(T)	350	3				1	1	2	3	3	4	4	6				
S-400T	450	3						1	2	2	2	2	3	4	4	5	
S-500T	550	3							1	1	1	2	3	3	3	4	5
S-600T	650	3										1	1	2	2	2	3
S-750T	800	3												1	1	1	2